



NOTES:

1. CONTRACTOR SHALL USE INDUSTRIAL VACUUM SYSTEM WITH WATER JET TO EXPOSE AND LOCATE UTILITY.
2. CONTRACTOR SHALL BACKFILL WITH CONTROLLED DENSITY FILL (FLOWABLE FILL) IN ACCORDANCE WITH MCDOT STANDARD SPECIFICATION 203.09 TO WITHIN 3-1/2" OF THE SURFACE, THEN FINISH WITH 2" TYPE 3 ASPHALT BINDER AND 1-1/2" TYPE 7 ASPHALT TOP.

UTILITY WINDOW

NOT TO SCALE

1/1/01

REVISED